

**JUSTIFICATION FOR NON-COMPETITIVE PROCUREMENT**

**COMPLETE THIS SECTION IF NEW CONTRACT(S)**

For contract(s) in this request, answer applicable questions in each of the 4 major subject areas below in accordance with the instructions for Preparation of Non-Competitive Procurement Form on the reverse side.

Request that negotiations be conducted only with Fluid Conserva-  
tion Systems (Name of Person or Firm) for the product and/or services described herein.  
This is a request for:  (One-Time Contract per Requisition # 03W190, copy attached) or  Term Agreement or  Delegate Agency (Check one). If Delegate Agency, this request is for "blanket approval" of all contracts within the \_\_\_\_\_ (Attach List) Pre-Assigned Specification No. \_\_\_\_\_  
(Program Name) Pre-Assigned Contract No. \_\_\_\_\_

**COMPLETE THIS SECTION IF AMENDMENT OR MODIFICATION TO CONTRACT**

Describe in detail the change in terms of dollars, time period, scope of services, etc., its relationship to the original contract and the specific reasons for the change. Indicate both the original and the adjusted contract amount and/or expiration date with this change, as applicable. Attach copy of all supporting documents. Request approval for a contract amendment or modification to the following:

Contract #: \_\_\_\_\_ Company or Agency Name: \_\_\_\_\_

Specification #: \_\_\_\_\_ Contract or Program Description: \_\_\_\_\_  
Mod #: \_\_\_\_\_ (Attach List, if multiple)


<u>Richard Patrick</u>	<u>(312) 744-5067</u>	<u>Richard Patrick</u>	<u>Water</u>	_____
Originator Name	Telephone	Signature	Department	Date

Indicate SEE ATTACHED in each box below if additional space needed:

<input type="checkbox"/> PROCUREMENT HISTORY <p style="text-align: center;">See Attachment 1</p>
<input type="checkbox"/> ESTIMATED COST ( Attachment 2 ) (\$20,400.00) 2 year warranty maintenance agreement for 6-TriCorr 2001 systems
<input type="checkbox"/> SCHEDULE REQUIREMENTS <p style="text-align: center;">A.S.A.P.</p>
<input type="checkbox"/> EXCLUSIVE OR UNIQUE CAPABILITY <p style="text-align: center;">See Attachment 3</p>
<input type="checkbox"/> OTHER

APPROVED BY: Cecilia Morales \_\_\_\_\_ DATE \_\_\_\_\_ BOARD CHAIRPERSON \_\_\_\_\_ DATE \_\_\_\_\_  
for OR DESIGNEE

## Attachment 1



Fluid Conservation Systems

July 8, 2003

Richard Patrick  
City Of Chicago  
Jardine Water Purification Plant  
1000 East Ohio Street  
Chicago, IL 60611

RE: TriCorr Description for Extended Warranty Contract


Dear Richard,

FCS is a 24 year-old company specializing in premier leak detection products. We were the first to patent leak noise correlator technology in 1978, and we continue to develop breakthrough products and technologies. FCS has been providing leak detection products and service to the City of Chicago for over 18 years. The city's current correlator, the TriCorr™ 2001 has been in service in the City of Chicago for 7 years.

The TriCorr™ 2001 processes amplified leak noise from two highly sensitive sensors placed on each side of the suspected leak position. The sophisticated leak noise correlation process uses basic operator-supplied pipe data to pinpoint the leak location and display the results on a large, easy to read LCD screen.

Should you have additional questions, please contact me at 800-531-5465.

Sincerely,

  
Thomas J. McGee  
Director Of Operations

## HEADQUARTERS OFFICE

2001 FORD CIRCLE • SUITE F • MILFORD, OH 45150 USA

TEL (513) 831-9335 • (800) 531-5465 • FAX (513) 831-9336


<http://www.fluidconservation.com>

HALMA GROUP  
COMPANY

## Attachment 2

**ECM Renewal Quotation****Fluid Conservation Systems Inc.**

2001 Ford Circle  
 Suite F  
 Milford, OH USA 45150  
 Phone (513) 831-9335 Fax (513) 831-9336



Fluid Conservation Systems

QUOTATION NUMBER: 03.174

QUOTATION DATE: 03/11/03

To: Tom Brooks  
 City Of Chicago  
 Field Eng. Service Section, 3rd Floor  
 2352 S. Ashland Ave  
 Chicago, IL 60608

From: Tim O'Connor

QUOTATION NO.	FREIGHT	SHIP VIA	F.O.B. POINT	TERMS
03.174	Prepay/Add	UPS Ground	Origin	Net 30

ITEM #	QTY	DESCRIPTION	PRICE EA. \$	TOTAL \$
1	6	1 Year Correlator Extended Warranty Maintenance Renewal	\$ 3,300	\$19,800
2	6	2 Year Correlator Extended Warranty Maintenance Renewal	\$ 3,400	\$20,400
OTHER TERMS:			SUBTOTAL	
• Pricing valid on orders placed prior to 09/26/03			SHIPPING	
•			OTHER	
			TOTAL	

Authorized by \_\_\_\_\_


Date \_\_\_\_\_

Purchase Order No. \_\_\_\_\_

HEADQUARTERS OFFICE  
 2001 FORD CIRCLE • SUITE F • MILFORD, OH 45150 USA  
 TEL (513) 831-9335 • (800) 531-5465 • FAX (513) 831-9336  
<http://www.fluidconservation.com>

HALMA GROUP  
 COMPANY

Attachment 3



Fluid Conservation Systems

July 8, 2003


Richard Patrick  
City Of Chicago  
Jardine Water Purification Plant  
1000 East Ohio Street  
Chicago, IL 60611

Dear Richard,

This letter serves to certify that Fluid Conservation Systems Inc. (FCS) is the only manufacturer of the TriCorr™ 2001 Leak Correlator System that is currently being used by the City of Chicago. As such, and due to the fact that we do not authorize our products repair, upgrade, or replacement sales to outside sources, FCS is the sole source for these items.

The manufacturer, Fluid Conservation Systems, is the only company capable of servicing an extended warranty for the TriCorr™ 2001 Leak Correlator System. FCS is the sole source for this service. Please give me a call at 1-800-531-5465 if you have any questions.

Sincerely,

  
Thomas J. McGee  
Director Of Operations

HEADQUARTERS OFFICE  
2001 FORD CIRCLE • SUITE F • MILFORD, OH 45150 USA  
TEL (513) 831-9335 • (800) 531-5465 • FAX (513) 831-9336  
<http://www.fluidconservation.com>

A  
HAWAIIAN  
COMPANY