


CITY OF CHICAGO

DEPARTMENT OF BUILDINGS

CODE MEMORANDUM

To: Department of Buildings Plan Examiners and Inspectors

From: Judith Frydland 
Commissioner

Date: February 8, 2016

Re: **TRESPA Meteon Wall Cladding Panels**

TRESPA Meteon is a high pressure laminate (HPL), rain-screen exterior wall cladding material. This material has an ASTM E-84 Flame Spread and a Smoke Development of 5, and has passed the ASTM-E-119-98 that covers the use of TRESPA cladding over a one hour (1) rated wall where the wall maintained its hourly rating.

This material is approved for use as exterior wall cladding for buildings of 4 stories or less subject to the requirement that TRESPA shall be installed over wall construction with a minimum fire rating of one (1) hour.