



To: Department of Buildings Plan Examiners and Inspectors

From: Judith Frydland
Commissioner

A handwritten signature in blue ink, appearing to be "JF", is written over the name "Judith Frydland".

Date: June 2, 2016

Re: **Plenum Air Terminal Units**

Effective immediately, plenum air terminal units which have been tested, listed and labeled by a city of Chicago recognized electrical testing laboratory under U.L. Standard 1995, will be accepted by the Bureau of Electrical Inspection without modification.

All electrical connections to plenum air terminal units must be performed by a registered electrical contractor under the authority of a permit issued by the Department of Buildings.

The Bureau of Electrical Inspection will continue to accept those products which have been previously approved by the Bureau under an "Equipment Approval" number ('E' Number).